



Philippine Economic Zone Authority

Roxas Boulevard corner San Luis St., Pasay City

Telefax No. 551-9587

e-mail: bac@peza.gov.ph

website: www.peza.gov.ph

**PROJECT: REHABILITATION OF STREET LIGHTING SYSTEM AT PAMPANGA
ECONOMIC ZONE (PEZA-HO-2013-03)**

BID BULLETIN No. 01

(20 March 2013)

This Bulletin is issued to modify or amend the Bid Documents and shall form an integral part of the Bid Documents.

- 1) Section VI. Specifications/Terms of Reference, **Clause 2.1** is hereby revised to add the following items:
 - e) The designer/contractor shall also prepare a separate design using solar panels as the power source of the street lights including the necessary support attachments. Likewise, the designer shall include the estimated project cost of the solar panel construction as well as the potential savings for the next twenty (20) years.
 - f) The designer/contractor shall prepare an inventory list of all existing street lights including the condition of its various components (not limited to street light poles, mast arm, luminaire, etc.) and conduct the necessary test prior to its re-utilization.
 - g) Using the most economical design/financial considerations, the designer/contractor shall prepare a work schedule based on their actual findings to validate and/or confirm the quantities indicated in the summary of bid proposal. This will determine the total project cost and possible change orders/variation orders prior to the actual project implementation.
 - h) For new materials that will be procured (not limited to street pole, mast arm and luminaries, wires, etc.), the designer/contractor shall secure all necessary test and/or certification that these materials passed the minimum quality standards set by the industry.
- 2) Section VI. Specifications/Terms of Reference, **Clause 2.2** is hereby revised to add the following items:
 - g) Preferably to ensure quality of works, all existing street lights (post, mast arm and luminaire) that will be re-used in this project shall be removed, repaired, rehabilitated, painted and tested prior to re-installation and/or relocation. Note, each street light component (e.g. pole, mast arm and luminaire) can be interchanged and/or mixed so as to form one (1) complete street light unit.

- h) Repair, rehabilitation and painting will include among others but not limited to patching/welding the corroded pipe/material; sanding and/or sand blasting corroded areas, applying primer and two coats of paint, replacement of busted luminaire, etc.
- 3) Except for the Perimeter Lighting Detail, all other drawings included in the original Bid Documents are hereby disregarded. The attached drawings/diagrams will be the official drawings/diagrams for this project (Site Plan, Single Line Diagram, Load Schedule).
- 4) Section VIII. Bill of Quantities of the original Bid Documents is hereby disregarded. The attached Bid Proposal Summary Form together with the Unit Price Analysis Form/Unit Price Analysis Derivations will be used in lieu of the BOQ.

For guidance and information of all concerned.

(Sgd.) J. PORFIRIO LL. YUSINGCO
BAC Chairman