

# BID BULLETIN NO. 1

24 February 2012

## PROJECT: "SUPPLY AND DELIVERY OF SIXTY NINE (69) PCS. CURRENT TRANSFORMERS FOR TRANSCO-CEZ"

---

This Bulletin is issued to modify or amend the Bid Documents. This shall form an integral part of the Bid Documents.

- a. Bidders must submit Certification that the offered units shall have been in service or proven use in the Philippines for the last three (3) years attached with supporting documents
- b. Authenticated Manufacturer's Certificate of Authorization (kindly bring original copy for verification purposes during the Bid Opening)
- c. Minimum Window Diameters:

RATIO	MINIMUM WINDOW DIAMETER (mm)
600:5	75
1200:5	100
1500:5	120
2000:5	120
2500:5	140
3000:5	140

- d. Amendment of the “**burden**” of all the current transformers to be **1.8** only, which is already the highest in the metering standard.

For your information and guidance.

**LEVI D. VIZMANOS**  
**Chairperson, CEZ BAC**