

# **BID BULLETIN NO. 1**

13 July 2012

**PROJECT: "SUPPLY AND DELIVERY OF SIXTY (60) PCS. FUSE CUT-OUTS AND FORTY FOUR (44) PCS. LIGHTNING ARRESTERS FOR TRANSCO-CEZ"**

---

This Bulletin is issued to modify or amend the Bid Documents. This shall form an integral part of the Bid Documents.

1. Adjustment of technical specifications on Lightning Arrester from 34.5 KV rated to 22 KV rated.
2. Schedule of Requirements for Lightning Arrester

Polymer Insulator based Lightning Arrester can be accepted. However, the items to be supplied must be applicable to tropical environment and all requirements for the porcelain insulator type must be complied.

Please be guided accordingly.

**LEVI D. VIZMANOS**  
Chairperson, CEZ - BAC