

# **BID BULLETIN NO. 1**

28 November 2012

## **PROJECT: "SUPPLY AND DELIVERY OF CAPACITOR BANKS FOR TRANSCO-CEZ"**

---

This Bulletin is issued to modify or amend the Bid Documents. This shall form an integral part of the Bid Documents.

1. Quantity of Lightning Arrester, Fuse Cut-out and Frame

The unit of measure, 'set', for Lightning Arrester, Fuse Cutout and Frame is for single item with complete accessories, such as L-bracket and fuse link. Surge counter is not included.

2. Records of testing

The required tests are the manufacturer's test report and on-site integrity validation.

3. Warranty period

Warranty period starts from acceptance of the project.

4. Factory acceptance test abroad need not to be witnessed. Manufacturer's certificate to be submitted.

Please be guided accordingly.

**LEVI D. VIZMANOS**  
Chairperson, CEZ - BAC