

BID BULLETIN NO. 2

04 December 2012

PROJECT: "SUPPLY AND DELIVERY OF CAPACITOR BANKS FOR TRANSCO-CEZ"

This Bulletin is issued to modify or amend the Bid Documents. This shall form an integral part of the Bid Documents.

1. Parallel units of 1-100KVAR and 1-50KVAR capacitor bank for the 150KVAR bank are acceptable. However, the supplier should ascertain that such configuration would not result to any technical problem once it is in operation. A demonstration shall be carried out prior to acceptance. Frame and connection requirements will be included as per frame minimum requirements at item no. 3.
2. The 19,920 Volts is the voltage specification of each 150KVAR capacitor. CEZ power distribution system voltage is 34,500 Volts.
3. The minimum requirement listed for the capacitor bank frame are
a) minimum spacing of 50mm between broad faces, b) minimum clearance between energized parts of 380mm for phase to phase and c) 250mm for phase to ground.

Please be guided accordingly.

LEVI D. VIZMANOS
Chairperson, CEZ - BAC