



## **Philippine Economic Zone Authority**

Roxas Boulevard corner San Luis St., Pasay City

Telefax No. 551-9587

e-mail: bac@peza.gov.ph

website: www.peza.gov.ph

**PROJECT: UPGRADE/REHABILITATION OF EXISTING FIRE SPRINKLER SYSTEM OF PEZA HEAD OFFICE BUILDING (PEZA-HO-2013-01)**

### **BID BULLETIN No. 02**

(21 January 2013)

This Bulletin is issued to modify or amend the Bid Documents and shall form an integral part of the Bid Documents.

- 1) To answer the query of Aztek Construction Firm on whether they can propose horizontal pumps instead of the required vertical pumps, the BAC's official reply is "No". Bidders must meet the minimum required specifications of the pumps stated in the bid documents.

For guidance and information of all concerned.

**(Sgd.) J. PORFIRIO LL. YUSINGCO**

BAC Chairman