









angeles livelihood center



Legend:
* 250W HPS Street light to be restored




PERIMETER LIGHTING DETAIL




CONCRETE FOUNDATION DETAIL

ISOMETRIC




PIPING LAYOUT FOR ROAD CROSSING



STREET LIGHTING REHABILITATION
 LOCATION: PAMPANGA

To be tapped at existing
 main distribution
 panel @ Admin Bldg

2 - 8.0 mm² THHN
 20 mm Ø PVC Conduit



NOTE: ALL BRANCHES WILL BE IN 8 mm²
 FOR VOLTAGE DROP CONSIDERATION

SINGLE LINE DIAGRAM

PROJECT : PAMPANGA ECONOMIC ZONE AUTHORITY
 STREET LIGHTING REHABILITATION
 LOCATION: PAMPANGA

Panel : SL-PP-A (TYPICAL TO SL-PP-B)
 Location :
 Enclosure: NEMA3R
 MAIN CB: 150AT
 FEEDER: 2-30mm² THHN+3.5G
 CONDUIT SIZE: 50mm O PVC
 VOLTAGE: 230
 PHASE: 2

CKT NO.	LOAD DESCRIPTION	VA	AMPERES	VOLTS	CKT BREAKER		FEEDER (THHN)	CONDUIT
					AT	POLES		
1	7 - 250W HPS L.Outlet	2500	10.87	230	20	2	2-8.0mm ² THHN +3.5mm ² G	20mm Q/PVC
2	7 - 250W HPS L.Outlet	2500	10.87	230	20	2	2-8.0mm ² THHN +3.5mm ² G	20mm Q/PVC
3	7 - 250W HPS L.Outlet	2500	10.87	230	20	2	2-8.0mm ² THHN +3.5mm ² G	20mm Q/PVC
4	7 - 250W HPS L.Outlet	2500	10.87	230	20	2	2-8.0mm ² THHN +3.5mm ² G	20mm Q/PVC
5	7 - 250W HPS L.Outlet	2500	10.87	230	20	2	2-8.0mm ² THHN +3.5mm ² G	20mm Q/PVC
6	7 - 250W HPS L.Outlet	2500	10.87	230	20	2	2-8.0mm ² THHN +3.5mm ² G	20mm Q/PVC
7	7 - 250W HPS L.Outlet	2500	10.87	230	20	2	2-8.0mm ² THHN +3.5mm ² G	20mm Q/PVC
8	7 - 250W HPS L.Outlet	2500	10.87	230	20	2	2-8.0mm ² THHN +3.5mm ² G	20mm Q/PVC
9	7 - 250W HPS L.Outlet	2500	10.87	230	20	2	2-8.0mm ² THHN +3.5mm ² G	20mm Q/PVC
10	7 - 250W HPS L.Outlet	2500	10.87	230	20	2	2-8.0mm ² THHN +3.5mm ² G	20mm Q/PVC
11	SPARE							
12	SPARE							
TOTAL		25000	108.7					

COMPUTATION:
 $I = \frac{2500}{230} = 108.7$ Amperes

VOLTAGE DROP CALCULATION: SINGLE P PHASE
 $VD = \frac{2 \times L \times R \times I}{1000}$

7 - 250W PER CKT @ 8mm² THHN
 $VD = \frac{2 \times 394 \times 1.28 \times 7.6}{1000}$
 $= 7.69$ VOLTS
 $VD\% = \frac{7.69}{230} \times 100 = 3.30\%$

L = Length of cable in ft.
 R = Resistance factor from NEC Chapter 9 Table 8
 where 30mm² = .201 ; 8.0mm² = 1.28
 V = Voltage Source
 $VD = \frac{VD}{SOURCE VOLTAGE} \times 100$

NOTE: PART OF ALV RD CKT, ADMIN LOOP AND 1ST STREET TO BE TAPPED @ ADMIN SOURCE