



Philippine Economic Zone Authority

Bids and Awards Committee (BAC) BID BULLETIN NO. 1 – s.2016

July 22, 2016


PROJECT: "Supply and Delivery of Two (2) Units 50HP Submersible Pump and Motor at The Cavite Economic Zone Pump Station"
(Reference No. PEZA-CEZ 16-07-008)

This Bid Bulletin is issued to modify or amend the following provisions in the Bidding Documents, as a result of the Pre-Bid Conference held on July 20, 2016 for the Project "Supply and Delivery of Two (2) Units 50HP Submersible Pump and Motor at the Cavite Economic Zone Pump Station". This shall form an integral part of the Bid Documents.

- Amendment / Clarification / Changes on:**
 - Section VII (Page 55) – Technical Specifications

Concern Raised	Amendment/Changes
<ul style="list-style-type: none"> Efficiency Ratio Requirement 	<ul style="list-style-type: none"> Efficiency ratio requirement for the submersible pump must be at least 70%-85% rate
<ul style="list-style-type: none"> Extension on delivery period from sixty 60 calendar days to ninety (90) calendar days 	<ul style="list-style-type: none"> Adjustment of the delivery period to Ninety (90) calendar days.
<ul style="list-style-type: none"> Pump capacity for One (1) unit 50HP submersible Pump and Motor <ul style="list-style-type: none"> 480 GPM against 380ft. head 	<ul style="list-style-type: none"> Pump capacity of 480gpm against 380 ft head for One (1) unit submersible Pump and Motor shall be replaced with: <ul style="list-style-type: none"> 450 GPM against 349 ft. head <p>thus;</p> Pump capacity for Two (2) units 50HP Submersible Pump and Motor shall now be at: <ul style="list-style-type: none"> 450 GPM against 349 ft. head for two (2) units

For guidance and information of all concerned.


LEVI D. VIZMANOS
 Chairperson, CEZ – BAC

