



BIDS AND AWARDS COMMITTEE (BAC)

BID BULLETIN NO. 01

25 October 2021

“CONSTRUCTION OF BCEZ MULTI-PURPOSE CENTER” (PR21-10-064)

This Bulletin is issued to augment/clarify the specifications set by the office on the items for bidding as discussed during the Pre-bid Conference held on October 22, 2021, 9 am at the Baguio City Economic Zone Administration Building, and via Microsoft Teams.

1. The First Aider requirement may be of any profession as long as he/she complies with the Red Cross Certificate of Training in compliance to the DOLE requirements.
2. The required experience for Safety officer is **three (3)** years.
3. The Curriculum Vitae format is being provided together with this Bulletin for uniformity and ease of evaluation.
4. The DUPA format to be followed shall be that from the DPWH.
5. Barracks intended for the workers of the project is prohibited within the Baguio City Economic Zone. Prospective bidders are advised to review Annex 3 of the project's uploaded bidding documents.
6. The contractor/supplier has the option where to tap water and power. For PEZA Water Application, it will be at the Engineering and Maintenance Division (1st floor), and the Electrical Application will be at TRANSCO which is at the 3rd Floor of the PEZA Admin Bldg. Further details are indicated in the Bidding Documents' Annex 3.
7. It is highly appreciated if the bidding documents to be submitted by the supplier has ear tabbing matching that with their table of contents for easier review of the BAC and TWG.
8. Concerns brought out about the electrical plans details will be updated and be part of this Bid Bulletin as Annexes. The updated electrical plans will replace sheet no. 34,35 & 36 of drawings on Bid Docs.
9. Conduits are RSC or Equivalent.
10. No grounding conductor for feeders and outlets at the Comfort Rooms have no GFCI Protection.
11. The PEZA-BCEZ requirement of Tanguile Flooring for the court shall be retained.
12. PEZA shall provide a standard format for the List of Equipment.
13. Sealing and Marking of bids are still required. The plastic is more of a precaution brought about by the pandemic.
14. NCII Certificates for the Plumber, Welder, Electrician are not necessarily required, as PEZA will be looking at the years of experience.

Please be guided accordingly.

(SGD)ENGR. PAUL M. CODAMON
BCEZ BAC Chairperson