Republic of the Philippines
PHILIPPINE ECONOMIC ZONE AUTHORITY

Bid Bulletin No. 01
30 October 2025

Reference Number: BCEZProc2025-124

Project Title: Supply, Delivery and Installation of Generator Set for BCEZ Multi-Purpose Building

This Bid Bulletin is issued pursuant to Section 34.3(d) of the IRR of Republic Act No. 12009, this Bid Bulletin is hereby issued to clarify and address matters discussed during the Pre-Bid Conference held on October 30, 2025.

The following matters are presented below for clarification:

ITEM NO.	CONCERN/REQUEST	REFERENCE	CLARIFICATION/ RESOLUTION
1	Required sound level	Section VII. Technical Specifications, Page 67 of the Bidding Documents	The required sound level shall not exceed **seventy-five (75) decibels (dB)** when measured **within ten (10) meters** from the generator set enclosure.
2	Will the delivery of the goods adhere to the schedule of 'on or before 31 December 2025'?	Invitation to Bid Item No. 2, Page 11 of the Bidding Documents	Yes. The delivery of the goods **shall be completed on or before 31 December 2025**, in accordance with the allocation of funds for the current fiscal year.
3	Submission of Latest Business Tax Return	Section III. Bid Data Sheet ITB Clause 27.1, Page 44 of the Bidding Documents	The parenthetical **"(ITR)"** in **"Latest Business Tax Return (ITR)"** is deleted for clarity. (Applicable for bidders with less than six (6) months of operations).

By the Rules, all other related provisions in the Bidding Documents that are correspondingly affected by these clarifications are likewise deemed amended to conform to this Bid Bulletin.

Amendments made herein shall be considered an integral part of the Bidding Documents.

ATTY. BERNADETTE M. QUITORIANO
Chairperson, BCEZ-BAC