



Republic of the Philippines
Philippine Economic Zone Authority

Bid Bulletin No. 01
6 May 2024

Reference Number: PR24-04-121
OPERATION AND MAINTENANCE OF BCEZ SEWAGE TREATMENT PLANT

Issued pursuant to Sec. 22. 5 of the IRR of R.A. 9184 to clarify and/or amend certain provisions in the Bidding Documents issued for this project, considering the issues raised and clarifications made by the prospective bidders during the Pre-Bid Conference held on May 3, 2024.

A. CLARIFICATIONS

ITEM NO.	CONCERN/REQUEST	REFERENCE	CLARIFICATION/ RESOLUTION
1.	Typographical Error: Legal Basis	Section VII Technical Specifications > Page 43 > Compliance Monitoring	DAO 2019-19 should be DAO 2021-19
2.	Will there be a staffhouse for STP Employees?		There is none. The Winning bidder and/or its employees shall be responsible in arranging an offsite staffhouse/lodging.
3.	What are the compliance parameters applicable to BCEZ per DAO 2016-08, Water Quality Guidelines and General Effluent Standards of 2016, and DAO 2021-19		Applicable parameters are the following: Ammonia, Nitrate, Phosphate, Biochemical Oxygen Demand (BOD), Fecal Coliform, Total Coliform, Oil and Grease, Surfactant (MBAS), Total Suspended Solids (TSS), Chemical Oxygen Demand (COD), pH, temperature, color, and odor.
4.	What is the existing/current STP design and/or process.		The BCEZ STP utilizes the Aerated Lagoon / Oxidation Process with Activated Sludge and Disinfection.
5.	Is PEZA-BCEZ VAT Registered.		Yes, PEZA-BCEZ is VAT Registered
6.	Can the ocular inspection be conducted anytime?		An ocular inspection is highly encouraged and scheduling of such would need to be coordinated with Ms. Mariam Vanessa A. Meneses of the BCEZ EHSD.

By Rules, all other related provisions in the Bidding Documents correspondingly affected by these clarifications are likewise deemed amended to conform to this Bid Bulletin.

Amendments made herein shall be considered an integral part of the Bidding Document.


ATTY. BERNADETTE M. QUITORIANO
Chairperson, BCEZ-BAC