

Bid Bulletin No. 02 01 December 2023

Reference Number: PR23-11-255

## Construction of PEZA-BCEZ Multipurpose Center

Issued pursuant to Sec. 22. 5 of the IRR of R.A. 9184 to clarify and/or amend certain provisions in the Request for Quotation issued for this project, considering the issues raised during the meeting last 30 November 2023.

## A. CLARIFICATIONS

NO.	CONCERN/ REQUEST	REFERENCE	CLARIFICATION/ RESOLUTION
1.	Sleeping Quarters		Not allowed within the zone/site.
2.	Comfort Rooms		Contractor will set-up/provide its own comfort rooms.
3.	Specifications	Item C.1. – Structural Concrete (Ready Mix, Class AA - 28 Mpa = 4,000 Psi @ 28 Days) (Foundations, Slabs, Columns and Beams)  • Table for Deficiency in Strength of Concrete Specimens, Percent (%)	Amendment:  Table for the Deficiency in Strength of Concrete Specimens, Percent (%) is not applicable with this item. (The table is only applicable for minor structures).  Minimum Concrete Compressive Strength shall be 4,000 psi / 28 Mpa at 28 days  Pouring Permit is required before concrete pouring.
4.	Specifications	Item C.2. – Structural Concrete (Ready Mix, Class A - 24 Mpa = 3,500 Psi @ 28 Days) (Slab on Grade, Stairs, Genset Foundation, Canal, Retaining Wall, Path Walk, Catch Basin, Lean Concrete, Manholes, and Lintel Beams)  Table for Deficiency in Strength of Concrete Specimens, Percent (%)	Amendment:  Table for the Deficiency in Strength of Concrete Specimens, Percent (%) is not applicable with this item. (The table is only applicable for minor structures).  Minimum Concrete Compressive Strength shall be 3,500 psi / 24 Mpa at 28 days  Pouring Permit is required before concrete pouring.

By Rules, all other related provisions in the Bidding Documents correspondingly affected by these clarifications are likewise deemed amended to conform to this Bid Bulletin.

Amendments made herein shall be considered an integral part of the Bidding Document.





