

BID BULLETIN NO. 01

November 4, 2016

**Project Title: "OIL REGENERATION OF 20/25 MVA TRANSFORMER AT
PEZA-BCEZ SUBSTATION #3"
(BC-2016-10-058)**

This Bid Bulletin is issued to amend and modify items in the Bidding Documents. This shall form an integral part of the Bid Documents.

From	To
Acidity Max - 0.03 mgKOH/gm (P. 58 – Technical Specifications)	Acidity Max – less than 0.1 mgKOH/gm
Completion of the Works is required within one (1) calendar day upon receipt of Notice to Proceed. (P. 3 – Invitation to Bid)	Completion of the Works is required within seven (7) calendar days upon Scheduled date by PEZA.

For the guidance and information of all concerned.

(Sgd.)
ATTY. RENE U. BAYSA
Bids and Awards Committee
Chairman