



Bids and Awards Committee (BAC)  
**BID BULLETIN NO. 1 – s.2021**

18 March 2021

**PROJECT: “Construction of Mold Technology Support Center Building at the Cavite Economic Zone”**  
(Reference No. CEZITB 2021-03-004)

This Bid Bulletin is issued to modify or amend the following provisions in the Bidding Documents, as a result of the Pre-Bid Conference held on 17 March 2021 for the Project “Construction of Mold Technology Support Center Building at the Cavite Economic Zone”.

The amendment is outlined as follows:

**A. ITEMS MODIFIED AS PER SPECIFICATIONS IN THE ORIGINAL PLAN**

No.	As Per Plan	Modified
1	3mm Thk x 300mm x 300mm Vinyl tiles on Fiber Cement Board	2mm Thk x 300mm x 300mm Vinyl tiles on Fiber Cement Board
2	Windows – 10mm Thk. Glass on Powdercoated Finish Aluminum Frame	Windows – 6mm Thk. Glass on Analok Aluminum Frame
3	Toilet Partition – 10mm Thk. Industrex Glass with Aluminum Frame in Powdercoated Finish	Toilet Partition – Phenolic Compact Boards
4	S/S Domestic Water Tank 2,500 Gallons w/ stainless steel ladder and support bracket	S/S Domestic Water Tank 1,000 Gallons w/ stainless steel ladder and support bracket
5	Water Pump 2.0Hp, 40psi, 220V, Single Phase (Goulds Pump Red Jacket)	Water pump 1.5Hp, 40psi, 220V, Single Phase (Goulds Pump Red Jacket)



## B. ITEMS EXCLUDED FROM THE CONSTRUCTION PLAN


No.	Particulars
1	Pavement/ Driveway/ Sidewalk
2	Perimeter Fence
3	Generator Pad
4	Guardhouse
5	Aircon units
6	Telephone and Data
7	Fire Detection and Alarm System
<i>Note: Equipment's listed in A-09 to be supplied by 3<sup>rd</sup> party</i>	

## C. Additional Details/Correction:

1. Additional details in structural plan page S-3, the depth of footing is 1.2m from the Natural Grade Line (Finish Grade Line as per plan). An additional depth of 1.6m from Natural Grade Line to Finish Grade Line, with a total depth of 2.8m from Finish Grade Line. The additional 1.6m depth is backfilled to be done by a 3rd party outsource developer.
2. Correction to the structural detail of service entrance post (MC1 at page S-3), the vertical bars is 20mmØ (not 28mmØ).

This Bid Bulletin No. 1 s.2021 shall amend all inconsistent provisions of the bid documents and shall form an integral part of the bidding documents issued for this project.

For the guidance and information of all concerned.



**LEVI D. VIZMANOS**  
Chairperson  
CEZ Bids and Awards Committee (CEZBAC)