



# PHILIPPINE ECONOMIC ZONE AUTHORITY

**Bid Bulletin No. 1**  
**December 6, 2021**

**Reference Number: PR21-11-090**

## **Installation of Wet Stand Pipe for SFB-1 and SFB-2**

Issued pursuant to Sec. 22. 5 of the IRR of R.A. 9184 to clarify and/or amend certain provisions in the Bidding Documents issued for this project, considering the issues raised and clarifications made by the prospective bidders during the Pre-Bid Conference held on <date> likewise, respond to bidder's written queries received within the prescriptive period for filing.

### **A. CLARIFICATION/S**

<b>ITEM NO.</b>	<b>CONCERN/REQUEST</b>	<b>REFERENCE</b>	<b>CLARIFICATION/ RESOLUTION</b>
<b>DURING THE PRE-BID CONFERENCE</b>			
1.	Will projects with piping lots/works be considered in the computation of the SLCC considering that these do not reflect piping/fire protection works in its Project titles?	Instruction to Bidders, Section 5.2	Yes. Contracts showing scope of work/s can be attached.
2.	What is the level of Accreditation for the Safety Officer applicable to the project?	Bid Data Sheet Section 10.4	As long as the SO complies with the standards set by the DOLE.
3.	Hard Copies of Bidding Documents	Instruction to Bidders, Section 16	PEZA requests 1 additional hard copy from the bidders
4.	Water and Electricity		The winning bidder can opt to apply for Water and Electricity resources from PEZA.
5.	Gate Valve Standard	Section VI. Specifications, Item E.9 –E.11	The gate valve shall be "UL listed" or its approved equal.

By Rules, all other related provisions in the Bidding Documents correspondingly affected by these amendments are likewise deemed amended to conform to this Bid Bulletin.

Amendments made herein shall be considered an integral part of the Bidding Document.

**ENGR. PAUL M. CODAMON**  
Chairperson, Bids and Awards Committee