



BIDS AND AWARDS COMMITTEE (BAC)

BID BULLETIN NO. 01

4 November 2020

“PROPOSED RE-PIPING PROJECT FOR WATER SUPPLY LINE AT BCEZ SFB COMPOUND” (PR20-09-85)

This Bulletin is issued to augment/clarify the specifications set by the office on the items for bidding as discussed during the Pre-bid Conference held on November 3, 2020, 2 pm at the Baguio City Economic Zone Administration Building.

1. Threaded portions of GI Pipes must be cut before welding any joint connections.
2. There will be leak and pressure tests after pipe connections have been done.
3. Detailed estimates should reflect the unit prices of construction materials, labor rates and equipment rentals used, indicating also the direct and indirect costs.
4. As per procurement manual for Infrastructure Projects, discounts may be offered and reflected on the Bid Form. In which case, discounts can be considered when computing for the total calculated bid price, as can be gleaned from Section 32.2.4 of the IRR of RA 9184. Discounts stated in the Bid Form allow bidders to itemize the application of discounts that are not yet reflected in the amounts specified in its bill of quantities and detailed estimates, vis-a-vis the program of works.
5. A contractor with an on-going application for renewal for PCAB license is considered ineligible to bid for the project.
6. The required lifting equipment shall not be used to lift or transfer transformers on the site. Specifications of equipment to be provided shall be at the discretion of the supplier.
7. The winning bidder shall secure PEZA Zone Passes for each and every personnel that will work on the project. Temporary Zone Passes which are valid for at least 6 months cost ten (10) pesos only.
8. Trade tests for skilled personnel, especially the welder, will commence after the receipt of the winning bidder of the Notice to Proceed.

Please be guided accordingly.

ENGR. PAUL M. GODAMON
BCEZ BAC Chairperson